

Calcium Hypochlorite 65%

ITEMS	STANDARD	TEST RESULTS
Appearance	White, free flowing granular product	Conforms
Available Chlorine %	$\geq 65\%$	66%
Direct Moisture %	5.5-10	8%
CaCl ₂ %	≤ 2.0	0.78%
CaCO ₃ %	≤ 3.0	0.92%
Ca(OH) ₂ %	≤ 2.0	0.78%
NaCl %	$\leq 20\%$	14.5%

The material complies as per above specification

